

# MTA Power Outage Response

*Not Yet Approved by Specialist*

September 1, 2009

**Please notify the appropriate contact personnel, in the event of a glitch or power outage. If at any point in this procedure something does not work, call the appropriate personnel for assistance.**

**1. Contact Personnel as necessary:**

- Cryogenics personnel – Michael Geynisman
- RF Expert – Al Moretti
- External Beams Department Head - Craig Moore
- External Beams MTA Experts – Tom Kobilarcik
- Mechanical Support – Ben Ogert

**2. As soon as power is restored and controls return:**

- a. **VACUUM:** Recover vacuum. Start pumps up as needed.
- b. **WATER:** Make sure that LCW systems are up and running.
- c. **RESTORES:** Do a restore any differences for crates.

**3. When the water systems are recovered and stable:**

- a. **POWER SUPPLIES:** Turn on the power supplies.

**4. When all systems are stable:**

- a. Make sure that everything is on and running normally.

**NOTES:** Please use this area to note problems encountered during recovery.